

## **CB TEST** CERTIFICATE

Ref. Certificate No.

IT-12333

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:

IMQ S.p.A.

Product:

Switches

Applicant:

**GIOVENZANA** 

STRAWINSKYLAAN

The Netherlands

Hungary

INTERNATIONAL BV 1105

1077 XX

**ELECTRA** 

**AMSTERDAM** Via Spluga, 2

Italy

ENGINEERING SRL 23889 S. MARIA HOE' LC

Factory:

Manufacturer:

G.G.H. KFT-GIULIO

**DEAK FERENC UT 9** 3036

GIOVENZANA HUNGAR

GYONGYOSTARJAN

Rating and principal

characteristics:

2P; 3P; 4P - Ith-Ithe 100A (C080) - Ith-Ithe 85A (C063) - Icm 2000A - Icw

1200A (1s) - Uimp 8kV - Ui 690V (see

Test Report on page 35)

Trade mark (if any):

GG (logo) GIOVENZANA



Model/Type reference:

Series C080 - C063 (See Test Report on pages 36 and 37)

Additional information:

This CBTC supersedes the preceding one No. IT-8313 of 2009-05-05

Sample of product tested to be in conformity with IEC: 60947-1(ed.5);am1 60947-3(ed.3);am1

Test Report Ref. No:

MAIMQAGCERMI120072137-02

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.

Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

read our ch

Date of issue: 2012-10-29

