

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC23107393268

Valid from: Jun.20,2023

Valid until: Dec.31,2028

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Giovenzana International B. V. Strawinskylaan 1105-1077XX Amsterdam,NL
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Highly Electric Co.,LTD.Chung Ho Factory 5F/5,2-359,Zhongshan Road,,Chung-Ho Distric,Xin-Bei City,Taiwan
NAME AND LOCATION OF THE FACTORY	Highly Electric Co.,LTD.Chung Ho Factory 5F/5,2-359,Zhongshan Road,,Chung-Ho Distric,Xin-Bei City,Taiwan
PRODUCT NAME, MODEL AND SPECIFICATION	Control switch FCT Ui: 500V; Uimp: 2.5kV; lth: 10A(Cable), 4A(M12 joint); FCT2XXXXXD/ FCTXXXXXD: (Cable) AC-15: Ue/le: AC120V/3A, AC240V/1.5A; DC-13: Ue/le: DC125V/0.55A, DC240V/0.27A; FCTMXXXXXD: (M12 joint) AC-15: Ue/le: AC120V/3A, AC240V/1.5A; DC-13: Ue/le: DC125V/0.55A, DC240V/0.27A; FCT2XXXXX: (Cable) AC-15: Ue/le: AC120V/6A, AC250V/4A, AC400V/3A; DC-13: Ue/le: DC24V/2.5A, DC125V/0.55A, DC250V/0.27A; IP67 Note: DC24V is not within the scope of CCC certification. See the appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.5-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑泉

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

